

# Laboratory for Fire Safety

## EN 13823 - SBI - Test results

program version v4.22 03-12-25 JM

### Project data

Project no: Y3366#AuraH01\_20260526  
 Print date: 3-6-2026 09:02:49  
 Test date: 26-05-2026  
 Technician: DDe

Measured data read from file(s):  
 Y3366#AuraH01\_20260526.txt  
 20260526.spr

### Description of product and mounting

Identification sample: Aura  
 Test specimen no.: #01  
 Substrate: CaSi  
 Mounting: End-use  
 Seams/joints: Horizontal

### Description of specimen tested

Harvest  
 Horizontal  
 Colour: Glory Sand  
 Screw system

### Recorded events during the test

Surface flash: N  
 Falling of parts of the specimen: N  
 Smoke not entering the hood: N  
 Mutual fixing of backing boards fails: N  
 Conditions justify early termination: N  
 Distortion or collapse of the specimen: N  
 Any other additional events: none

### Visual observations during the test

Lateral flame spread till edge of specimen: N  
 Flaming droplets/particles <= 10 s: N  
 Flaming droplets/particles > 10 s: N

### Results

Figra 02: 60,76 W/s at: 381 s  
 Figra 04: 38,09 W/s at: 441 s  
 THR600: 4,35 MJ  
 Smogra: 33,22 m2/s2 at: 372 s  
 TSP600: 440,11 m2

### The test specimen complies with classes

Fire behaviour: **B**  
 Smoke production: **s3**  
 Falling droplets: **d0**

*Classification in accordance with EN 13501-1 requires:  
 Class A2: 3 SBI-tests and EN ISO 1716 or EN ISO 1182  
 Class B/C/D: 3 SBI-tests and EN ISO 11925-2*

### Classification limits

Fire:	A2/B	C	D
Figra0.2:	<=120		
Figra0.4:		<=250	<=750
THR600:	<=7,5	<=15	
LFS:	<edge	<edge	
Smoke:	s1	s2	s3
Smogra:	<=30	<=180	not s1/s2
TSP600:	<=50	<=200	not s1/s2
Drop./Part.:	d0	d1	d2
flaming droplets/particles	none	<=10 s	not d0/d1

## Laboratory for Fire Safety EN 13823 - SBI - Heat release


program version v4.22 03-12-25 JM

### Project data

Project no: Y3366#AuraH01\_20260526  
Print date: 3-6-2026 09:02:49  
Test date: 26-05-2026  
Technician: DDe

Measured data read from file(s):  
Y3366#AuraH01\_20260526.txt  
20260526.spr

### Heat release and Figra



## Laboratory for Fire Safety EN 13823 - SBI - Smoke production

program version v4.22 03-12-25 JM

### Project data

Project no: Y3366#AuraH01\_20260526  
Print date: 3-6-2026 09:02:49  
Test date: 26-05-2026  
Technician: DDe

Measured data read from file(s):  
Y3366#AuraH01\_20260526.txt  
20260526.spr

### Smoke production and Smogra

